


### SPECIFICATION SHEET

# KICKSPACE HEATERS MODELS 112 & 114



## Low-profile design provides floor-level heat from out-of-the-way locations.

#### FEATURES

- Attractive white finish
- Vertical louvers disperse heat evenly
- Front-mounted, snap action, bimetallic thermostat (Model 112 only)
- Heavy-duty, steel sheathed, plate-finned element
- Factory-wired for 240 VAC, 1500W
- Field-convertible to operate on 120 VAC, 750 or 1500W
- Mounts into standard kickspaces beneath cabinets, vanities, counters, stairways, etc.

ACCESSORIES (purchase separately)

- Model 86W Line-Voltage Thermostat
- Model 59W / 59V 60 Minute Timer
- Model 61W / 61V 15-Minute Timer
- Model 90 Built-in Thermostat Kit (Model 114 only)

#### SPECIFICATIONS

| VOLTS | WATTS | AMPS | BTU/HR | SHIPPING<br>WEIGHT |
|-------|-------|------|--------|--------------------|
| 240   | 1500  | 6.2  | 5120   | 12 lbs.            |
| 120   | 750   | 6.2  | 2560   |                    |
| 208   | 1125  | 5.4  | 3840   | 12 100.            |
| 120   | 1500  | 12.5 | 5120   |                    |

BOLD ratings are factory-wired.

#### **TYPICAL SPECIFICATION**


The heater shall be Broan Model 112 (Model 114).

Unit shall have heavy-gauge steel housing and grille with white finish.

Heater will have heavy-duty, steel-sheathed, plate-finned element. Heater will have front-mounted thermostat (Model 112 only).

Heater to deliver 1500 watts of fan-forced heat from 240 VAC circuit. It must be convertible to operate on 120 VAC, full or half-wattage.

Heater shall be U.L. Listed.





Broan-NuTone LLC, 926 West State Street, Hartford, WI 53027 (1-800-637-1453)

| REFERENCE | QTY. | REMARKS | Project                |      |
|-----------|------|---------|------------------------|------|
|           |      |         | Location               |      |
|           |      |         | Architect              |      |
|           |      |         | Engineer<br>Contractor |      |
|           |      |         |                        |      |
|           |      |         | Submitted by           | Date |